

Hazardous Location Push Button Specifications

Bulletin Numbers 800G, 800H, and 800R

Topic	Page
800H Type 7&9 Hazardous Location Push Buttons	
Specifications (Bul. 800H)	5
Momentary Contact Push Buttons Units (Bul. 800H)	9
Push Pull Units (Bul. 800H)	13
Selector Switch Units (Bul. 800H)	17
Pilot Light Devices (Bul. 800H)	21
Specialty Units (Bul. 800H)	23
Station Design Guidelines (Bul. 800H)	25
Approximate Dimensions & Shipping Weights (Bul. 800H)	27
800R 30.5 mm Push Button Stations Hermetically Sealed for Division 2	
Specifications (Bul. 800R)	33
Approximate Dimensions & Shipping Weights (Bul. 800R)	36

Topic	Page
800G Hazardous Location Push Buttons	
Specifications (Bul. 800G)	37
Complete Assembled Stations (Bul. 800G)	42
Configurable Ganged Assembled Stations (Bul. 800G)	43
Push Button Units (Bul. 800G)	44
Selector Switch Units (Bul. 800G)	46
Pilot Lights (Bul. 800G)	47
Enclosures (Bul. 800G)	48
Back-of-Panel Components (Bul. 800G)	49
Approximate Dimensions (Bul. 800G)	51

Additional Resources

These documents contain additional information concerning related products from Rockwell Automation.

Resource	Description
Industrial Automation Wiring and Grounding Guidelines, publication 1770-4.1	Provides general guidelines for installing a Rockwell Automation industrial system.
Product Certifications website, http://www.rockwellautomation.com/global/certification/overview.page	Provides declarations of conformity, certificates, and other certification details.

You can view or download publications at <http://www.rockwellautomation.com/literature/>. To order paper copies of technical documentation, contact your local Allen-Bradley distributor or Rockwell Automation sales representative.





Product Description (Bul. 800H)

Application

When properly mounted in a Type 7 & 9 enclosure, Bulletin 800H Type 7 & 9 operators are designed to meet the requirements of the National Electrical Code for Class I, Divisions 1 & 2, Groups B, C & D Hazardous Gas; Class II, Divisions 1 & 2, Groups E, F and G Hazardous Dust; and, Class III Hazardous Fiber Locations. In addition, the single-gang shallow base, Cat. No. 800H-IHZX7, meets Class I, Group B requirements. This Type 7 & 9 equipment is listed by Underwriters Laboratories, Inc.

Per National Electrical Code:

Zone 1: In Class I, Zone 1 locations, all wiring methods permitted for Class I, Division 1 locations and Class I, Zone 0 or Zone 1 locations, including requirements for sealing, shall be permitted.

Zone 2: In Class I, Zone 2 locations, all wiring methods permitted for Class I, Division 2, Class I, Division 1 or Division 2, and Class I, Zone 0 or Zone 1 locations, including requirements for sealing, shall be permitted.

Operator Construction

The Allen-Bradley line of hazardous location devices features copper-free (less than 0.4 of 1% copper content) die cast aluminum bushings and mounting rings, Type #316 stainless steel operating shafts and an O-ring seal for added corrosion resistance. These components mount into a threaded hole (3/4 in.-14 NPSM) in a suitable enclosure.

Bulletin 800H Type 7 & 9 components are available in two basic formats: standard barrel (Bulletin 800H) and long barrel (Bulletin 800HL). Standard barrel devices are suitable for mounting in panel thickness up to 1 in. thick. Long barrel devices are suitable for mounting in panel thickness greater than 1 in. and no thicker than 2-1/2 in. Both style operators offer a unique locking bracket, which provides an anti-turn feature to prevent the operator from coming loose. The mounting rings in front of the panel are knurled to provide a second way to tighten each unit into the panel.

Outdoor Use

Bulletin 800H Type 7 & 9 stations and enclosures are not configured for outdoor use as standard. A Type 3 rating is available, while maintaining Type 7 & 9 integrity of the enclosure, by the addition of a Type 3 sealing flange and an approved drain. The sealing flange that is shown in [Figure 1](#) can be purchased as an option or as an accessory. A Type 4 rating can be achieved by using sealing nuts to seal the push button operators along with the sealing flange. Sealing nuts are available as accessories (see our [website](#).)

Elimination of Conduit Seal Off Requirement

Bulletin 800H Type 7 & 9 units can be installed with various sealing options. By using a flanged sealing well, these stations can be installed without a conduit seal off in most applications (subject to applicable codes and laws). The sealing wells that are shown in [Figure 1](#) can be purchased as an option or as an accessory. Sealing wells have an integral Type 3 flange seal for outdoor applications.

Sealed switch contact blocks are another way to help eliminate the need for conduit seal fittings in most applications (subject to applicable codes and laws). Sealed switch contact blocks can be purchased as an option on assembled stations by changing the Bulletin No. from 800H to 800R. Sealed switch contact blocks can be ordered as an accessory (see our [website](#)). A push button station with a sealed switch contact block is shown in [Figure 1](#).

Figure 1 - Sealing Options

